

AGRICULTURAL WELL PERMIT INFORMATION

PERMIT EXPIRATION

The application for a permit will expire one (1) year after the date of issuance, if the work has not been started and reasonable progress is not made toward completion.

Well owners will be billed at the current hourly rate for any time incurred after the permit expiration date. Inspection time includes travel time to and from your well for inspections of surface slab and surface construction features.

CONTRACTOR RESPONSIBILITIES

It is the responsibility of the Well Contractor to construct, deepen, or reconstruct an agricultural well in accordance with Kern County Ordinance Code, Section 14.08, and the State Department of Water Resources' Bulletin 74-81 and Bulletin 74-90, except as modified by subsequent revisions. Representatives of the Environmental Health Division conduct routine inspections during the construction phase, to ensure that your well is constructed according to the regulations.

WELL OWNER RESPONSIBILITIES

Once the well has been constructed, deepened, or reconstructed by the contractor, you may obtain electrical permits from the Kern County Building Inspection Division, which will allow you to energize a pump once it is installed.

Although you may wish to contract with a water well contractor or pump company to do the following work, it is the responsibility of the owner of the well to supply the following items once the well has been completed:

- Surface slab
- Watertight sanitary seal
- Approved backflow protection device (chemigation, air gap)
- Down-turned, screened casing air vent
- Disinfection access/sounding tube
- Unthreaded sample tap
- Flow Meter – NSF 61 Approved
- Collect water samples from the well for the following Water Quality Analyses: Irrigation Water Analysis
- Arsenic Fluoride
- EDB (ethylene dibromide) DBCP (Dibromochloropropane) Gross Alpha

WATER TESTING LABORATORIES

Kern County Ordinance Code, Section 14.08, requires the water produced by a well is tested for bacteriological, radiological, and chemical quality prior to putting the well into service.

The Water Quality Analysis test must be performed by a state-certified laboratory.

The following laboratories can provide sample containers and instructions on how to collect water samples. Some laboratories will also collect water samples for you upon request.

BC Laboratories
4100 Atlas Court
Bakersfield, CA 93308
(661) 327-4911

BSK Analytical Laboratories
700 22nd Street
Bakersfield, CA 93301
(661) 327-0671

Dellavalle Laboratory, Inc.
1910 W. McKinley, Suite 110
Fresno, CA 93728
(559) 233-6129 or
(800) 228-9896

Midway Laboratory
315 Main Street
Taft, CA 93268
(661) 765-2364

Zalco Laboratories, Inc.
4309 Armour Avenue
Bakersfield, CA 93308
(661) 395-0539

FINAL CONSTRUCTION INSPECTIONS

A representative of the Environmental Health Division will make a final construction inspection to ensure the following surface construction features are present and properly installed.


Inspections are made by appointment only. Telephone (661) 862-8740 when you have verified that all the items listed below are present:

- ___ Watertight reinforced concrete surface slab - a minimum thickness of 6 inches, set a minimum of 4 inches above ground level, and extending horizontally at least 3 feet in all directions from the edge of the well casing. Must adequately drain water away from the casing;
- ___ Unthreaded sample spigot;
- ___ Down-turned, screened casing air vent;
- ___ A backflow protection device;
- ___ Disinfection access/sounding tube - allows access to well for chlorination or for determining depth to water without removing pump or well plate;
- ___ Watertight sanitary seal for all cracks, holes, or openings into the well;
- ___ Flowmeter – NSF 61 Approved.

FINAL APPROVAL

Final approval of your well cannot be issued until all water quality tests are received and the surface construction features approved.

DEEP WELL TURBINE INSTALLATION



SUBMERSIBLE PUMP INSTALLATION

