



BRYNN CARRIGAN
DIRECTOR

KRISTOPHER LYON, MD
HEALTH OFFICER

2700 M STREET, SUITE 300 BAKERSFIELD, CALIFORNIA 93301-2370 661-862-8740 WWW.KERNPUBLICHEALTH.COM

FA # _____

PR # _____

An inspection of the swimming pool/spa was conducted and the inspector was unable to verify that the GFCI was working correctly. Please verify and submit this form within 14 days to avoid a re-inspection fee as well as be subject to closure of the pool/spa.

Swimming Pool Electrical Inspection Report for GFCI

California Code of Regulation Article 79, section 25.69.20 Underwater Lighting Fixtures states
(a) A ground-fault circuit interrupter shall be installed in the branch circuit supplying underwater fixtures operating at more than 15 volts.

Name of Pool: _____

Address of Pool: _____

City, Zip Code: _____ Phone # _____

Manager/Contact: _____

Manager Mailing Address: _____

City, Zip Code: _____ Phone# _____

Email: _____

The undersigned certifies, under the penalty of perjury, to the safe installation of the GFCI which is in compliance with all applicable state laws and local ordinances.

Inspection completed by: _____

Type of Certification and number: _____